


Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE

Dated: 25.03.26

It is certified that an inspection team headed by Mr. Guddu (Chemist) (Name of Officer with designation) from U.P. Jal Nigam (Rural) Farrukhabad (Department name: PHED/CHC) inspected the PN Foundation School Near Shivaji ki Murti, Kaimganj Dist. Farrukhabad . (Name & Address of the School ) on 25.03.2026 (Date of The Inspection) and on the basis of water test report (Attached) Bearing No FBD/2026/776 Dated- 25.03.2026 of District Level Water Analysis Laboratory Farrukhabad (PHED Lab).

(Name of School ) PN Foundation School Near Shivaji ki Murti, Kaimganj Dist. Farrukhabad, Uttar Pradesh has safe drinking water facilities for the students and staff of the institution. The school also maintains proper hygienic sanitation conditions in the school building and the campus as per the norms prescribed by the Central/State/U.T. Government.

Signature with Seal:   
Name: Alia Verna  
Designation: Assistant Engineer  
Name & Address of the Office/Department: UPJN(R) Farrukhabad

ASSISTANT ENGINEER  
DIVISION OFFICE  
U.P. JAL NIGAM (RURAL)  
FARRUKHABAD

To,  
PN Foundation School  
Near Shivaji ki Murti, Kaimganj  
(Farrukhabad). Uttar Pradesh

Note: This certificate is to be issued by an authorized officer / PHED laboratory / local bodies based on drinking Summar water analysis report.





# District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural) Farrukhabad

Office of Executive Engineer, Division Office, U.P Jal Nigam,(Rural)  
Fauji Colony, Maseni Farrukhabad Pin- 209601



TC-13514

TEST REPORT(WATER)

Format No. – 7.8 F-01

Report No.41	Chemical Test/FBD/2026/776	Report Release Date	28.03.2026	Serial No.	41	Page 1/1
ULR NO.	TC-13514-2600000037F	Quality of Sample	Drinking Water			

## Customer Details

Office Name and Address	PN Foundation School Near Shivaji ki Murti, Kaimgarj Dist. Farrukhabad
Ref. Letter No. & Date	Letter No. 0 Date- 24.03.2026

## Details of Sample

District	Farrukhabad	Tehsil / Block	Kaimgarj
Gram Panchayat		Village	
Habitation		Location	Near Shivaji ki Murti
Source of Sample	Summer	Sample Code.	FBD/2026/776
Quantity of Sample	2 Litre	Date of Sample Collection	24.03.2026
Receiving Date	24.03.2026	Sampling Done By	Amit Kumar
Sample Depositer	Amit Kumar		
Sampling Method	IS 17614 (Part-I): 2023 ISO 5667-1:2023		
Analysis Start Date	25.03.2026	Analysis Completion Date	25.03.2026

## Environmental Condition

Temperature	25°C ± 3°C	27.4°C	Humidity	50% ± 15%	54%
-------------	------------	--------	----------	-----------	-----

## Technical Data of Analysis

S. No	Analysed Parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1.	Odour	-	A	Agreeable	Agreeable	IS 3025 (Part 05):2018
2.	Taste	-	A	Agreeable	Agreeable	IS 3025 (Part 8):2023
3.	pH@25°C	-	7.38	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electro. Method)
4.	Turbidity	NTU	1.74	1.00	5.00	IS 3025 (Part 10):2023
5.	Total Dissolved Solids(TDS)	mg/L	401	500	2000	IS 3025 (Part 16):2023
6.	Chloride (as Cl)	mg/L	88	250	1000	IS 3025 (Part 32):2025 (Argentometric Method)
7.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/L	74	200	600	IS 3025 (Part 23):2023
8.	Total Hardness (as CaCO <sub>3</sub> )	mg/L	302	200	600	IS 3025 (Part 21):2023 (EDTA Method)
9.	Sulphate (as SO <sub>4</sub> )	mg/L	32.25	200	400	APHA 24th Edition 4500-SO <sub>4</sub> Method E (Turbidimetric Method) 2023
10.	Nitrate (as NO <sub>3</sub> )	mg/L	15.74	45	45	APHA 24th Edition 4500-NO <sub>3</sub> :(UV Screening Method) 2023
11.	Fluoride (as F)	mg/L	0.398	1.00	1.50	APHA 24th Edition-4500-F Method C (Electrode Method) 2023
12.	Iron (as Fe)	mg/L	0.434	1.00	1.00	APHA 24th Edition 3500 – Fe Method B :2023 (Phenanthroline Method)
13.	Calcium (as Ca <sup>2+</sup> )	mg/L	69.73	75	200	IS 3025 (Part 40):2024 (EDTA Method)
14.	Magnesium (as Mg <sup>2+</sup> )	mg/L	31.10	30	100	IS 3025 (Part 46):2023
15.	Colour	Hazen	-	5	15	APHA 24th Edition 2120 Colour Method Platinum Cobalt Visual Comparison 2023

## Note-

1. This Certificate refers only to the particular sample(s) Submitted for testing.
2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated condition of measurements.
4. Sample will be stored up to 07 Days ( In case of non-perishable items only) from the date of issue of tests report unless otherwise specified.
5. BDL: Below Detection Limit.
6. Source is not verified by the Laboratory.

Report Prepared by


Deputy Quality Manager

Reviewed By

Chemist

Authorised Signatory

Mr. Guddu (Test Lab Incharge)



Laboratory Contact Details Email- labfarrukhabad@gmail.com , Mobile Number – 9870895993

\*\*\*End of the Report\*\*\*